



THE CITY OF SAN DIEGO

Fire and Life Safety Services

Sprinkler Policies Policy FS - 0207

Exposed Sprinkler Heads

All sprinkler heads installed in exterior locations, such as beneath canopies, porches, balconies, or in open parking garages shall be listed or approved as corrosion resistant. In addition, such heads shall be installed within 20 feet of any opening in enclosed garages.